



powered by  carmanah®

Transfer Switch TS-50

Owner's Manual




Table of Contents

| | |
|--------------------------------------|----|
| Introduction | 2 |
| Installation | 2 |
| Operational Testing | 7 |
| Troubleshooting | 7 |
| Hi-Pot Testing | 8 |
| Generator Note | 9 |
| Medical Appliances | 10 |
| Caution | 10 |
| Disclaimer of Liability and Warranty | 10 |

1. Introduction

The Go Power!™ Transfer Switch 50 (TS-50) provide automatic power switching between two or three separate 120/240 volt AC input sources, including power cords, onboard generators, onboard inverters, or all three. The ATS will sense the presence of available power supplies and automatically select the proper one.

The TS-50 can be installed at the electrical entry of the RV on the line side of the main distribution panel, or it can be installed on the load side of the panel between the main panel and a sub panel, allowing switching for either the entire electrical load or only designated circuits switch ground bar. A direct access hole to the ground bar is provided through the enclosure for convenience.

Determine proper connections of wire conductors to electrical terminals. On 120 VAC wiring the ground wire is bare or green, the neutral wire is white, and the hot wire is black. On 240 VAC

2. Installation

READ AND FOLLOW ALL SAFETY INSTRUCTIONS!

2.1 Disconnect Power

Make sure the generator is off, the external power cord is unplugged, and the inverter, if any, is shut off.

2.2 Mounting Location

The TS-50 mounting location may be on any interior surface where the unit will be out of direct weather. The chosen location must be accessible after installation is complete to facilitate future servicing. If possible, mount the TS-50 near the power cord entry or the location of the generator output. Typical locations include under counter cabinets, below closet compartments, inside the bed pedestal or cabinets, overhead cabinets, under-floor storage compartments accessed from the vehicle exterior, etc.

2.3 Electrical Preparation

Use knockouts 12, 5, and 6 when installing the TS-50. Do not use knockouts 3, 4, 7, and 8 when preparing the TS-50 for installation.

2.4 Mounting

Mount the TS-50 with screws through holes provided in bottom corners of the can. The unit should be screwed to a solid surface firmly enough to hold its weight during vehicle operation.

2.5 Electrical Connections

- A.** Attach an 8 gauge chassis ground wire to the transfer switch ground bar. A direct access hole to the ground bar is provided through the enclosure for convenience.
- B.** Determine proper connections of wire conductors to electrical terminals. On 120 VAC wiring the ground wire is bare or green, the neutral wire is white, and the hot wire is black. On 240 VAC wiring there are two hot wires; one is black, and the other is red.
- C.** Strip the outer jacket from all of the incoming cables. Strip insulation from all ends of the copper conductors. Insert cables through clamps in openings. Do not tighten cable clamps at this time.

-
- D.** Route internal ground wires around lower area of enclosure and secure to ground wires away from electrical contacts on components to avoid the possibility of electrical short-circuit.
- E.** Connect the ground wires to the ground bar. Tighten terminals to a minimum of 20 inch-pounds.
- F.** Connect the neutral (white) wire connections.
- G.** Connect the hot wire(s). If there is a black wire and a red wire (for 240 VAC), it does not matter which is hot 1 and which is hot 2.
- H.** In some applications it may be desirable to feed a 120 volt supply, such as an inverter, into both hot legs of a transfer switch, so that the 120 volt supply can operate the entire RV load. Although discretion is advised in designing this into the system, it is acceptable, as long as the connection to both hot legs is accomplished on the input side of the transfer switch. To do this, connect the hot from the 120-volt supply, such as an inverter, to hot 1, and then attach a jumper wire of the same gauge from hot 1 to hot 2. Consideration should be given to the following:
- The entire load must be 120 volt; you cannot operate a 240 volt load from a 120 volt supply.
 - There may be a load which would be undesirable to run from this particular 120 volt supply; that load should be isolated when the 120 volt supply is operating. The TS-50 is sometimes used as a 'lock-out' switch to prevent specific loads from being operated from designated supplies. Example: preventing a battery charger or air conditioner from running from an inverter, yet operating from generator or powercord.
- I.** Tighten cable clamps on switch enclosure.
- J.** Attach lid. The lid is designed to snap on and should not open without deliberate effort.

2.5.1 Installation Between Powercord and Generator (Configuration A)

The TS-50 is designed with an easy-to wire bridge. Refer to Diagram 1 for wiring lug designations.

1. Connect the powercord neutral to the powercord lug labeled NEUTRAL WHT.

-
2. Connect powercord hot 1 and hot 2 to powercord lugs HOT 1 BLK and HOT 2 RED.
 3. Connect the generator neutral(s) to generator lug labeled NEUTRAL WHT.
 4. Connect generator hot 1 and hot 2 to generator lugs HOT 1 BLK and HOT 2 RED.
 5. Connect output to panel or other destination to the applicable “panel” lugs. The bypass switch should be in the “off” position (marked “1”).

2.5.2 Installation Between Inverter and Alternating Source (Configuration B)

For installation between an inverter (default) and another power supply (dominant), such as the output from a prior powercord/ generator transfer switch, connect the inverter neutral to “powercord” lug labeled NEUTRAL WHT, and connect the inverter hot to “powercord” lugs labeled HOT 1 BLK and HOT 2 RED. Connect the alternate power supply neutral to “generator” lug NEUTRAL WHT.

Connect alternate power supply hot 1 and hot 2 to “generator” lugs HOT 1 BLK and HOT 2 RED. Connect the output to applicable “panel” lugs. These connections will allow any other supply to dominate the inverter, and the inverter output will pass through the normally closed contacts of the switch. This allows the inverter to operate only in the absence of the other power supplies, which is ideal for inverters. Set the timer delay bypass switch of the inverter/alternate source transfer switch to the ON position.


2.5.3 Installation In Hybrid System With TS-30 For Designated Circuits (Configuration C)

Install the TS-50 on the line side of the main distribution panel as illustrated in Configuration A. The TS-30 can be installed between inverter (default) and a circuit panel supplied by the larger amp alternating power supply (dominant). Connect the inverter to terminals 7 and 8, and connect the 30-amp branch circuit to 5 and 6.



Connect the designated circuit panel to the output terminals. The inverter will only supply the load in the absence of the 50 amp power supply, in which case, only the load designated to the 30 amp branch circuit is supplied. The timer delay bypass switch on the TS-30 should be in the ON position.

Diagram 1

Use copper wire only
75° C minimum






CONFORMS TO
ANSI/UL STD. 800
CERTIFIED TO CSA
100.01-2019



WARNING
MULTIPLE 120/240 VOLT POWER SOURCES.
ALL SOURCES MUST BE SECURED OFF
BEFORE SERVICING. REFER SERVICE TO A
QUALIFIED ELECTRICIAN.

NOTE
120/240 VOLT TRANSFER RELAYS MAY NOT
OPERATE IF POWER IS LOST ON ONE HOT
LEG WHEN RUNNING ON 240 VOLTS.

When protected by a modified case circuit
breaker rated 30 amps or less, this line/
generator switch is rated for use on a circuit
capable of delivering not more than 5000
symmetrical amperes.



3. Operational Testing

READ AND FOLLOW ALL SAFETY INSTRUCTIONS

1. Plug in the powercord. If the main panel circuit breakers are switched on, RV load should operate normally. Unplug the powercord.
2. Start the generator. There is a pre-programmed 20-30 second delay in the transfer switch. The delay is designed to allow the generator a brief warm-up period. When the delay completes its cycle the switch should engage and the RV load should operate normally. An audible click should sound as the switch engages.
3. Shut down the generator. As the generator winds down the switch should disengage without chatter or cycling. An audible click should sound as the switch disengages.
4. Plug in the powercord. Start the generator. After the preprogrammed delay, the switch should transfer power automatically from the powercord to the generator. Listen for the audible click as the switch transfers, as there will likely be no other indication that the switch has engaged. Shut down the generator and unplug the powercord.
5. On transfer switch arrangements with three power supplies, plug in the powercord, start the generator, and turn on the inverter. With all three supplies energized at the same time, the switch will select the generator for the primary supply choice. Shut down the generator. The switch will transfer to the powercord. Unplug the powercord. The switch will transfer to the inverter. The inverter should always be connected so that it is only selected in the absence of both the other supplies.

4. Troubleshooting

4.1 Low Voltage

Low voltage is harmful to most appliances. Contactor-based transfer switches are also affected by low voltage; if the voltage level drops far enough the contactor points will “chatter”. Sustained contact chattering can cause transfer switch damage. Switches that have been damaged by chattering need to be returned to the factory for replacement.

4.2 General Low Voltage

Low voltage can be caused by low voltage conditions such as an RV park with inadequate wiring for crowded camper conditions where everyone's electricity suffers (brownout). In this case a voltmeter will be helpful and will show a low voltage reading from the park receptacle, even before the RV is plugged in. When you experience general low voltage conditions, remember, that brownouts can be harmful to most appliances. A better alternative might be to utilize the generator until park voltage conditions improve.

4.3 Localized Low Voltage

Low voltage conditions can be caused by specific situations such as an additional cord that is too long and too small for the load. Do not attempt to extend the RV powercord by using a 16-gauge 100-foot extension cord, or any cord not rated for an RV-size load. A localized low voltage condition will result when a load is turned on that is larger for what which the cord is designed. As soon as the RV tries to draw more current than the amount for which the cord is rated, the voltage will fall within the length of the cord, and the RV will experience low voltage. This is especially noticeable during inrush current situations such as an air conditioner start-up. Contactor-based transfer switches are affected by this. The compressor will try to start, the voltage will drop, which will cause the contactor to drop out, at which point the voltage will rise to the pre-inrush level. The contacts will chatter when the A/C compressor kicks in, however the voltage may read normal.

Most meters are not fast enough to record this voltage drop. You can test for low voltage readings during this inrush cycle by reading voltage at the contactor terminals while manually holding the contactor plunger down in its closed position. This will override the chattering condition and the meter will have time to register the reduced voltage. If this condition exists, identify and correct the low voltage situation before proceeding further.

4.4 Physical Interference

Some transfer switch models have wiring connections made by wire nuts on 63 leads. Occasionally on these models, the wiring connections will get folded into the cbox in such a manner that the wiring will interfere with the physical operation of the relay. Visually inspect for free operation of the relay(s).

5. Hi-Pot Testing

(MANUFACTURING COMPANIES ONLY)

NOTE: If the hi-pot test is performed from the plug on the powercord, the test may only hi-pot the cord itself; it may not test the RV wiring beyond the switch. The hi-pot test should be performed from either the transfer switch output or from the main panel. Test as follows:

1. Turn on all circuit breakers in the panel.
2. Make sure the generator is off.
3. Make sure the powercord is unplugged. Verify that the prongs on the powercord plug are protected so that the hipot voltage won't cause a fault reading from a short, or cause bodily injury from electrical shock.
4. Turn off or disconnect all appliances that would be damaged by the hi-pot test.
5. Connect the hi-pot leads to:
 - a) Transfer switch ground bar
 - b) Transfer switch output terminals hot 1, hot 2 (if present), and neutral.
6. Energize the hi-pot and conduct test. This will hi-pot test for leakage (short) between the current-carrying conductors and the ground in the entire 120/240 VAC circuitry beyond the transfer switch. In most cases it will also test the powercord itself. Turn off the hi-pot.
7. Do not test the transfer switch generator input. The hi-pot will damage the time delay control module in the transfer switch. If the generator wires to the switch must be checked, disconnect the generator wires from the transfer switch and connect hi-pot test leads to the loose wires. Reconnect wires after testing.
8. If hi-pot test fails, there is a short in the system. The next step is to isolate the location of the short. Turn off the main breaker in panel and hi-pot test again. If the test still fails, the fault is between the switch and the panel. Test cord for shorted plug. If the test passes, turn on the main breaker, and turn on all branch breakers except one. Retest each branch circuit individually until the shorted circuit is isolated. Repair the fault and retest. The hi-pot test is successful when there are no more fault indications.

6. Generator Note

It is never advisable to start or stop a generator under load. To prolong the life of this transfer switch, and the life of the air conditioner, microwave oven and other appliances, always turn those appliances off before starting or stopping the generator.

7. Medical Appliances

Go Power!™ will not knowingly sell a Go Power!™ Automatic Transfer Switch for any life-support application. It is strongly recommended that you do not operate any life support equipment from a transfer switch. If the switch should malfunction, or fail to operate due to other external conditions, it is possible that all connected appliances, including any life support equipment, will also shut down, resulting in a risk of medical complications and potential loss of life.

8. Caution!

Do not install this or any electrical accessory in the battery compartment, or a compartment intended for storing flammable liquids or liquids that produce flammable or explosive fumes such as gasoline, etc. There are components in the Transfer Switch that, in their normal operation, may cause arcing. In addition, the act of turning on a light switch or unplugging the cord on an electrical appliance can cause a spark, which can ignite any combustible liquids or vapors. Therefore, do not install a transfer switch in a compartment intended for storing flammable liquids, and never store flammable liquids inside a compartment containing any electrical device.

9. Disclaimer of Liability & Warranty

Visit www.gpelectric.com for additional product warranty information.

All Go Power!™ Transfer Switches come with a two-year warranty. Go Power!™ warranties all Go Power!™ Transfer Switches in the continental United States and Canada from defects in materials or workmanship under normal use for two years from date of retail purchase and will repair or replace any Go Power!™ Transfer Switch under warranty found to be defective free of charge. This warranty is not valid against defects resulting from, but not limited to:

- Misuse and/or abuse, neglect, or accident
- Exceeding the unit's design limits
- Improper installation, including, but not limited to, improper environmental protection and improper hook-up
- Acts of God, including lightning, floods, earthquakes, fire and high winds

-
- Damage in handling, including damage encountered during shipment or installation
 - Outdoor weather

9.1 Repair and Return Information

Visit www.gpelectric.com to read the “frequently asked questions” section of our website to troubleshoot the problem. If trouble persists:

1. Call your Go Power![™] Technical Support team (1-866-247-6527).
2. Return defective product to place of purchase



© 2011 GO POWER!™ By Carmanah Technologies
www.gpelectric.com

MOBI_MAN_GP-TS-50_vA_Dec2011