



Ω OMEGA™ User's Guide

PLATINUM™ Series



*Shop online
at
omega.com*

*e-mail: info@omega.com
For latest product
manuals:
www.omega.com/en-us/pdf-manuals*

CN32Pt, CN16Pt, CN16DPt, CN8Pt, CN8DPt, CN8EPt

DP32Pt, DP16Pt, DP8Pt, DP8EPt

Load & Save File Format



omega.com info@omega.com

Omega Engineering, Inc:

800 Connecticut Ave. Suite 5N01, Norwalk, CT 06854, USA

Toll-Free: 1-800-826-6342 (USA & Canada only)

Customer Service: 1-800-622-2378 (USA & Canada only)

Engineering Service: 1-800-872-9436 (USA & Canada only)

Tel: (203) 359-1660

Fax: (203) 359-7700

e-mail: info@omega.com

**Omega Engineering,
Limited:**

1 Omega Drive, Northbank,
Irlam Manchester M44 5BD
United Kingdom

**Omega Engineering,
GmbH:**

Daimlerstrasse 26 75392
Deckenpfronn Germany

TABLE OF CONTENTS

1	Introduction	4
1.1.	Purpose	4
1.2.	Definition of Terms and Acronyms	4
2	File Format	5
2.1.	Meta Records	5
2.1.1	User Meta-records	6
2.2.	Comments	6
2.3.	Data records	6
2.1.2	Item Field	6
2.1.3	Value Field	6
2.4.	Device Configuration Records	6
2.5.	Example File (Partial Excel)	7
3	Parameter Name List	7

1 Introduction

1.1. Purpose

The following document defines the file format used by the Platinum series LOAD and SAVE commands.

The Save command is intended to capture the configuration of a Platinum series controller and save it on removable media (i.e., USB Stick memory).

The Load command is intended to read a configuration image from an external device (i.e., USB memory stick) and store it on a Platinum device.

The file format used is an ASCII text file, with tab delimiters between each field. These files may be reviewed or modified using a simple text editor or application programs such as Microsoft Excel, that support reading tab delimited files.

1.2. Definition of Terms and Acronyms


I2C	2-wire serial interface	ADC	Analog to Digital Converter
Base Device	Device connected to slave device	DAC	Digital to Analog Converter
Smart Input	Device supporting 1 or more Input sensors	RS485	Electrical signals used for serial communications
Smart Output	Device supporting 1 or more Output Elements	RS232	Electrical signals used for serial communications
Sensor Element	One of the physical sensing elements on a Smart Output	CSV	Comma Separated Values
AC	Alternating Current	COTS	Commercially-Off-The-Shelf
DC	Direct Current	ESD	Electro Static Discharge
CS	Chip Select	FW	Firmware
RS232	Electrical signals used for serial communications	HW	Hardware
CSV	Comma Separated Values	I/O	Input/output
COTS	Commercially-Off-The-Shelf	LED	Light Emitting Diode
ESD	Electro Static Discharge	Hexadecimal	Values expressed using base 16 (2 ⁴)

2 File Format

The file format uses multiple records with each record having one or more fields. The 'tab' character is used to separate fields within a record. All data information is represented by ASCII strings. Each record is terminated by a CR/LF (0xd/0xa) character sequence.

Records fall into three general categories:

- 1) Comment / blank records
- 2) Keyword records
- 3) Data records

Record Type	Tag Character	Use	Example
Meta Record	%	Defines operations/information other than data records	%File <tab> Platinum_0000.txt
Comment	//	Allow users to insert comments to document files	// This is a comment
Blank Line		Allow separating blocks of information	
Data record	<any printable character>	Defines data to be read or written	INPUT_SENSOR <tab> 2
 The first record within the file must contain the Keyword %Platinum.			

2.1. Meta Records

The following Meta Records are defined:

Meta Record	Load Function	Save Function
%Platinum	Must be first record in the file	Generated as first record in the file
%File <tab> Platinum_xxxx.txt	Ignored	Generated based on file number entered by user
%Version <tab> yyy.yyyy.yyyy.yyy	Ignored	Records device F/W version information
%Date <tab> ...	Ignored	Not generated
%Author <tab> ...	Ignored	Not generated
%DeviceID <tab> xxxxxxxxx	Ignored	Generated based on internal DeviceID information
%Profile <tab> xx	Saves current Profile information and starts loading new R&S profile	Generated, xx = 00-99
%Segment <tab> xx	Saves current segment information and starts loading new R&S segment	Generated, xx = 1..8
%<user defined> <tab> ????	Ignored	Ignored

2.1.1 User Meta-records

Additional meta-records may be defined by the user. Upon loading, they will be ignored and the data will not be retained. User meta-records are not generated during the Save function.

Future versions of Platinum f/w may include support for Date Created, Date Loaded, Author and other meta-record information.

2.2. Comments

All text following a double slash (//) will be ignored. Users may add comment information on blocks of records on individual records following the data field.

Note that load function stops parsing the record after the data field has been captured. Extraneous characters following the data field will be ignored.

Blank records (lines) are ignored.

2.3. Data records

Data records consist of 2 fields, an *item* and a *value*, separated by a tab character.

Item <tab> Value

2.1.2 Item Field

The item field provides a named field from the device data base.

During the load operation unrecognized items will be ignored. This allows configuration files to be maintained across versions that introduce expanded items.

2.1.3 Value Field

The value field will be generate as either a floating point value (xx.x) or an unsigned 32-bit integer (xx). The parser will process all characters up to the first non-numeric character.

2.4. Device Configuration Records

Device Configuration records allow loading data that enable / disable specific device features.

Device Configuration records may only be written when the device serialization mechanism is in the **write enable** state. During a LOAD operation these records are ignored and device serialization mechanism is not in the **write enable** state.

During the SAVE operation all Device Configuration records as written to the file.

2.5. Example File (Partial Excel)

No.	File	
1	%Platinum	
2	%File	C:Platinum_0001.txt
3	%Device_ID	0
4	%Version	0.9.6.6
5	INPUT_SENSOR	0
6	TC_TYPE	1
7	RTD_WIRES	1
8	RTD_ACRV_OHM_TYPE	0
9	THERMISTOR_TYPE	0
10	PROCESS_RANGE	0
11	DB_4_20_MANUAL_LIVE	0
12	DB_4_20_MANUAL_READING_1	4

3 Parameter Name List

The following table summarizes all parameter names supported by the LOAD and SAVE file commands.

The data TYPE column key is:

L – Long (32 bit) integer

R – Short (16 bit) integer

F – Floating point value

Mnemonic	Type	Description
DEVICE_ID	L	Device Identifier
VERSION_NUMBER	L	Device Version (xxx.xxx.xxx.xxx)
INPUT_SENSOR	R	Enumerated sensor (input) type
TC_TYPE	R	Enumerated Thermocouple type
RTD_WIRE	R	Enumerated RTD wire type
RTD_ACRV_OHM_TYPE	R	Enumerated RTD Curve
THERMISTOR_VALUE	R	Enumerated Thermistor type
PROCESS_RANGE	R	Enumerated process input range
PROCESS_TYPE	R	Enumerated process type
DB_4_20_MANUAL_READING_1	F	Scale reading value 1

Mnemonic	Type	Description
DB_4_20_MANUAL_INPUT_1	F	Scale input value 1
DB_4_20_MANUAL_READING_2	F	Scale reading value 2
DB_4_20_MANUAL_INPUT_2	F	Scale input value 2
DB_0_24_MANUAL_READING_1	F	
DB_0_24_MANUAL_INPUT_1	F	
DB_0_24_MANUAL_READING_2	F	
DB_0_24_MANUAL_INPUT_2	F	
DB_10_MANUAL_READING_1	F	
DB_10_MANUAL_INPUT_1	F	
DB_10_MANUAL_READING_2	F	
DB_10_MANUAL_INPUT_2	F	
DB_1_MANUAL_READING_1	F	
DB_1_MANUAL_INPUT_1	F	
DB_1_MANUAL_READING_2	F	
DB_1_MANUAL_INPUT_2	F	
DB_POINT_1_MANUAL_READING_1	F	
DB_POINT_1_MANUAL_INPUT_1	F	
DB_POINT_1_MANUAL_READING_2	F	
DB_POINT_1_MANUAL_INPUT_2	F	
DB_POINT_05_READING_1	F	
DB_POINT_05_INPUT_1	F	
DB_POINT_05_READING_2	F	
DB_POINT_05_INPUT_2	F	
DB_TARE_MODE	R	Enumerated value – Enable/Disable/Remote
DB_NUMBER_LINEARIZATION_POINTS	R	Number of active Linearization points
DB_LINEARIZATION_READING_1	F	Linearization reading value 1
DB_LINEARIZATION_INPUT_1	F	Linearization input value 1
DB_LINEARIZATION_READING_2	F	Linearization reading value 2

Mnemonic	Type	Description
DB_LINEARIZATION_INPUT_2	F	Linearization input value 2
DB_LINEARIZATION_READING_3	F	Linearization reading value 3
DB_LINEARIZATION_INPUT_3	F	Linearization input value 3
DB_LINEARIZATION_READING_4	F	Linearization reading value 4
DB_LINEARIZATION_INPUT_4	F	Linearization input value 4
DB_LINEARIZATION_READING_5	F	Linearization reading value 5
DB_LINEARIZATION_INPUT_5	F	Linearization input value 5
DB_LINEARIZATION_READING_6	F	Linearization reading value 6
DB_LINEARIZATION_INPUT_6	F	Linearization input value 6
DB_LINEARIZATION_READING_7	F	Linearization reading value 7
DB_LINEARIZATION_INPUT_7	F	Linearization input value 7
DB_LINEARIZATION_READING_8	F	Linearization reading value 8
DB_LINEARIZATION_INPUT_8	F	Linearization input value 8
DB_LINEARIZATION_READING_9	F	Linearization reading value 9
DB_LINEARIZATION_INPUT_9	F	Linearization input value 9
DB_LINEARIZATION_READING_10	F	Linearization reading value 10
DB_LINEARIZATION_INPUT_10	F	Linearization input value 10
DB_SMARTSENSOR_SELECT	R	Selects Smart Sensor input
READING_DECIMAL_POSITION	R	Enumerated value – number of decimal points
DISPLAY_UNITS	R	Enumerated value – units of measure
DISPLAY_COLOR_NORMAL	R	Enumerated value to set display color
DISPLAY_BRIGHTNESS	R	Enumerated value to set display brightness
DB_RATE_MODE	R	Enumerated value
DB_ANNUNCIATOR_1_MODE	R	
DB_ANNUNCIATOR_2_MODE	R	
DB_ANNUNCIATOR_3_MODE	R	
DB_ANNUNCIATOR_5_MODE	R	
DB_ANNUNCIATOR_6_MODE	R	
DB_ANNUNCIATOR_7_MODE	R	

Mnemonic	Type	Description
READING_FILTER_CONSTANT	R	Enumerated input filtering constant
EXCITATION_VOLTAGE	R	Enumerated excitation control value
USB_PROTOCOL	R	
USB_RECOGNITION_CHARACTER	R	
USB_DATA_FLOW	R	
USB_ECHO_MODE	R	
USB_CONTINUOUS_DATA_PERIOD	F	
USB_DATA_FORMAT_STATUS	R	
USB_DATA_FORMAT_READING	R	
USB_DATA_FORMAT_PEAK	R	
USB_DATA_FORMAT_VALLEY	R	
USB_DATA_FORMAT_UNIT	R	
USB_SEPARATION_CHAR	R	
USB_LINE_FEED	R	
USB_DEVICE_ADDRESS	R	
USB_MODBUS_MODE	R	
USB_MODBUS_EOF	R	
ETH_PROTOCOL	R	
ETH_RECOGNITION_CHARACTER	R	
ETH_DATA_FLOW	R	
ETH_ECHO_MODE	R	
ETH_CONTINUOUS_DATA_PERIO	F	
ETH_DATA_FORMAT_STATUS	R	
ETH_DATA_FORMAT_READING	R	
ETH_DATA_FORMAT_PEAK	R	
ETH_DATA_FORMAT_VALLEY	R	
ETH_DATA_FORMAT_UNIT	R	
ETH_LINE_FEED	R	
ETH_SEPARATION_CHAR	R	
ETH_DEVICE_ADDRESS	R	
ETH_MODBUS_MODE	R	
ETH_MODBUS_EOF	R	

Mnemonic	Type	Description
SERIAL_PROTOCOL	R	
SERIAL_RECOGNITION_CHARAC	R	
SERIAL_DATA_FLOW	R	
SERIAL_ECHO_MODE	R	
SERIAL_CONTINUOUS_DATA_PE	R	
SERIAL_DATA_FORMAT_STATUS	F	
SERIAL_DATA_FORMAT_READIN	R	
SERIAL_DATA_FORMAT_PEAK	R	
SERIAL_DATA_FORMAT_VALLEY	R	
SERIAL_DATA_FORMAT_UNIT	R	
SERIAL_LINE_FEED	R	
SERIAL_SEPARATION_CHAR	R	
SERIAL_DEVICE_ADDRESS	R	
SERIAL_MODBUS_MODE	R	
SERIAL_MODBUS_EOF	R	
SERIAL_232_485	R	
SERIAL_BAUD_RATE	R	
SERIAL_PARITY	R	
SERIAL_DATABITS	R	
SERIAL_STOPBITS	R	
Safety Parameters		
TIME_FORMAT	R	Enumerated value to indicate time format
SAFETY_DELAYED_POWER_ON_RUN	R	Write 1 to DISABLE auto RUN on power up
SAFETY_DELAYED_OPER_RUN	R	Write 1 to DISABLE return to RUN in OPER
SAFETY_SETPOINT_LIMIT_LOW	F	Minimum allowed setpoint value
SAFETY_SETPOINT_LIMIT_HIGH	F	Maximum allowed setpoint value
LOOP_BREAK_ENABLE	R	Write 1 to enable loop break test
LOOP_BREAK_TIME	L	Time (msec) for break test
OPEN_CIRCUIT_ENABLE	R	Write 1 to enable open circuit test
Passwords		
PASSWORD_INIT_ENABLE	R	Write 1 to enable INIT menu password
PASSWORD_INIT	L	INIT menu password
PASSWORD_PROGRAM_ENABLE	R	Write 1 to enable PROG menu password

Mnemonic	Type	Description
PASSWORD_PROGRAM	L	PROG menu password
Setpoint Control		
SETPOINT_1_MODE	R	Enumerated Setpoint 1 mode
SETPOINT_1	F	Setpoint 1 value
SETPOINT_2_MODE	R	Enumerated Setpoint 2 mode
ABSOLUTE_SETPOINT_2	F	Setpoint 2 value (absolute mode)
DEVIATION_SETPOINT_2	F	Setpoint 2 value (derivative mode)
Output Configuration		
OUTPUT_1_HW_TYPE	R	
OUTPUT_1_MODE	R	
OUTPUT_1_ON_OFF_ACTION	R	
OUTPUT_1_SETPOINT	R	
OUTPUT_1_PULSE_LENGTH	F	
OUTPUT_1_ON_OFF_DEADBAND	F	
OUTPUT_1_OUTPUT_RANGE	R	
OUTPUT_1_RETRAN_READING_1	F	
OUTPUT_1_RETRAN_OUTPUT_1	F	
OUTPUT_1_RETRAN_READING_2	F	
OUTPUT_1_RETRAN_OUTPUT_2	F	
OUTPUT_2_HW_TYPE	R	
OUTPUT_2_MODE	R	
OUTPUT_2_ON_OFF_ACTION	R	
OUTPUT_2_SETPOINT	R	
OUTPUT_2_PULSE_LENGTH	F	
OUTPUT_2_ON_OFF_DEADBAND	F	
OUTPUT_2_OUTPUT_RANGE	R	
OUTPUT_2_RETRAN_READING_1	F	
OUTPUT_2_RETRAN_OUTPUT_1	F	
OUTPUT_2_RETRAN_READING_2	F	
OUTPUT_2_RETRAN_OUTPUT_2	F	
OUTPUT_3_HW_TYPE	R	
OUTPUT_3_MODE	R	
OUTPUT_3_ON_OFF_ACTION	R	
OUTPUT_3_SETPOINT	R	

Mnemonic	Type	Description
OUTPUT_3_PULSE_LENGTH	F	
OUTPUT_3_ON_OFF_DEADBAND	F	
OUTPUT_3_OUTPUT_RANGE	R	
OUTPUT_3_RETRAN_READING_1	F	
OUTPUT_3_RETRAN_OUTPUT_1	F	
OUTPUT_3_RETRAN_READING_2	F	
OUTPUT_3_RETRAN_OUTPUT_2	F	
OUTPUT_4_HW_TYPE	R	
OUTPUT_4_MODE	R	
OUTPUT_4_ON_OFF_ACTION	R	
OUTPUT_4_SETPOINT	R	
OUTPUT_4_PULSE_LENGTH	F	
OUTPUT_4_ON_OFF_DEADBAND	F	
OUTPUT_4_OUTPUT_RANGE	R	
OUTPUT_4_RETRAN_READING_1	F	
OUTPUT_4_RETRAN_OUTPUT_1	F	
OUTPUT_4_RETRAN_READING_2	F	
OUTPUT_4_RETRAN_OUTPUT_2	F	
Alarm Control		
ALARM_1_TYPE	R	
ALARM_1_MODE	R	
ALARM_1_DISPLAY_COLOR	R	
ALARM_1_HIGH_HIGH_MODE	R	
ALARM_1_LATCH_TYPE	R	
ALARM_1_CONTACT_CLOSURE_T	R	
ALARM_1_POWER_ON_STATE	R	
ABSOLUTE_ALARM_1_LOW	F	
ABSOLUTE_ALARM_1_HIGH	F	
DEVIATION_ALARM_1_LOW	F	
DEVIATION_ALARM_1_HIGH	F	
ALARM_1_HIGH_HIGH_OFFSET	F	
ALARM_1_ON_DELAY	F	
ALARM_1_OFF_DELAY	F	
ALARM_2_TYPE	R	
ALARM_2_MODE	R	

Mnemonic	Type	Description
ALARM_2_DISPLAY_COLOR	R	
ALARM_2_HIGH_HIGH_MODE	R	
ALARM_2_LATCH_TYPE	R	
ALARM_2_CONTACT_CLOSURE_T	R	
ALARM_2_POWER_ON_STATE	R	
ABSOLUTE_ALARM_2_LOW	F	
ABSOLUTE_ALARM_2_HIGH	F	
DEVIATION_ALARM_2_LOW	F	
DEVIATION_ALARM_2_HIGH	F	
ALARM_2_HIGH_HIGH_OFFSET	F	
ALARM_2_ON_DELAY	F	
ALARM_2_OFF_DELAY	F	
PID Parameters		
PID_ACTION	R	Enumerated PID control action
PID_MAX_RATE	F	PID maximum rate of change
PID_PERCENT_LOW	F	Minimum PID Control output value
PID_PERCENT_HIGH	F	Maximum PID Control output value
PID_ADAPTIVE_CONTROL_ENABLE	R	Write 1 to enable Adaptive Control
PID_AUTOTUNE_TIMEOUT	L	Timeout (msec) for auto tuning
PID_STABILITY_TIMEOUT	L	Autotune stability test timeout
PID_STABILITY_RATE	F	Autotune maximum rate of change stability test
Remote Setpoint Group		
RSP_ENABLE	R	
RSP_PROCESS_RANGE	R	
RSP_4_20_SETPOINT_MIN	F	
RSP_4_20_INPUT_MIN	F	
RSP_4_20_SETPPOINT_MAX	F	
RSP_4_20_INPUT_MAX	F	
RSP_0_24_SETPOINT_MIN	F	
RSP_0_24_INPUT_MIN	F	
RSP_0_24_SETPPOINT_MAX	F	
RSP_0_24_INPUT_MAX	F	
RSP_0_10_SETPOINT_MIN	F	
RSP_0_10_INPUT_MIN	F	
RSP_0_10_SETPOINT_MAX	F	

Mnemonic	Type	Description
RSP_0_10_INPUT_MAX	F	
RSP_0_1_SETPOINT_MIN	F	
RSP_0_1_INPUT_MIN	F	
RSP_0_1_SETPOINT_MAX	F	
RSP_0_1_INPUT_MAX	F	
Ramp & Soak Control		
RAMP_SOAK_PROFILE_SELECT	R	Starting Profile for Ramp and Soak
RAMP_SOAK_MODE	R	Enumerated – Ramp and Soak mode
Calibration Group		
TCAL_TYPE	R	Enumerated TCAL type
TCAL_ICE_POINT_OFFSET	F	Stored ICE POINT offset
TCAL_1_POINT_OFFSET	F	Stored 1 point CAL offset
TCAL_2_POINT_OFFSET	F	Stored 2 point CAL offset
TCAL_2_POINT_GAIN	F	Stored 2 point CAL gain
PID Tuning		
PID_P_	F	Proportional Gain value
PID_I_	F	Integral Gain value
PID_D_	F	Derivative Gain value
Simulation Group		
SIM_INPUT_MODE	R	
SIM_INPUT_RATE	R	
SIM_INPUT_ADJ	F	
SIM_INPUT_MAX	F	
SIM_INPUT_MIN	F	
SIM_INPUT_C0	F	
SIM_INPUT_C1	F	
SIM_INPUT_C2	F	
SIM_INPUT_C3	F	
SIM_AUX_INPUT_MODE	R	
SIM_AUX_INPUT_RATE	R	
SIM_AUX_INPUT_ADJ	F	
SIM_AUX_INPUT_MAX	F	
SIM_AUX_INPUT_MIN	F	
SIM_AUX_INPUT_C0	F	
SIM_AUX_INPUT_C1	F	

Mnemonic	Type	Description
SIM_AUX_INPUT_C2	F	
SIM_AUX_INPUT_C3	F	
Ramp & Soak Profile Info (repeated for profiles 1..99)		
SEGMENTS_PER_PROFILE	R	Number of segments in current profile
SOAK_ACTION	R	Enumerated – Soak Action
SOAK_LINK	R	Profile to link to after current profile
TRACKING_TYPE	R	Enumerated – R&S tracking type
Ramp & Soak Segment Info (repeated 8 times / profile)		
RAMP_EVENT	R	RE.ON flag set for current segment
SOAK_EVENT	R	SE.ON flag set for current segment
SOAK_PROCESS_VALUE	F	Target SOAK setpoint for current segment
RAMP_TIME	L	Time (msec) to reach target SOAK setpoint
SOAK_TIME	L	Time (msec) to hold at SOAK setpoint

WARRANTY/DISCLAIMER

OMEGA ENGINEERING, INC. warrants this unit to be free of defects in materials and workmanship for a period of **13 months** from date of purchase. OMEGA's WARRANTY adds an additional one (1) month grace period to the normal **one (1) year product warranty** to cover handling and shipping time. This ensures that OMEGA's customers receive maximum coverage on each product.

If the unit malfunctions, it must be returned to the factory for evaluation. OMEGA's Customer Service Department will issue an Authorized Return (AR) number immediately upon phone or written request. Upon examination by OMEGA, if the unit is found to be defective, it will be repaired or replaced at no charge. OMEGA's WARRANTY does not apply to defects resulting from any action of the purchaser, including but not limited to mishandling, improper interfacing, operation outside of design limits, improper repair, or unauthorized modification. This WARRANTY is VOID if the unit shows evidence of having been tampered with or shows evidence of having been damaged as a result of excessive corrosion; or current, heat, moisture or vibration; improper specification; misapplication; misuse or other operating conditions outside of OMEGA's control. Components in which wear is not warranted, include but are not limited to contact points, fuses, and triacs.

OMEGA is pleased to offer suggestions on the use of its various products. However, OMEGA neither assumes responsibility for any omissions or errors nor assumes liability for any damages that result from the use of its products in accordance with information provided by OMEGA, either verbal or written. OMEGA warrants only that the parts manufactured by the company will be as specified and free of defects. OMEGA MAKES NO OTHER WARRANTIES OR REPRESENTATIONS OF ANY KIND WHATSOEVER, EXPRESSED OR IMPLIED, EXCEPT THAT OF TITLE, AND ALL IMPLIED WARRANTIES INCLUDING ANY WARRANTY OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE ARE HEREBY DISCLAIMED. LIMITATION OF LIABILITY: The remedies of purchaser set forth herein are exclusive, and the total liability of OMEGA with respect to this order, whether based on contract, warranty, negligence, indemnification, strict liability or otherwise, shall not exceed the purchase price of the component upon which liability is based. In no event shall OMEGA be liable for consequential, incidental or special damages.

CONDITIONS: Equipment sold by OMEGA is not intended to be used, nor shall it be used: (1) as a "Basic Component" under 10 CFR 21 (NRC), used in or with any nuclear installation or activity; or (2) in medical applications or used on humans. Should any Product(s) be used in or with any nuclear installation or activity, medical application, used on humans, or misused in any way, OMEGA assumes no responsibility as set forth in our basic WARRANTY/DISCLAIMER language, and, additionally, purchaser will indemnify OMEGA and hold OMEGA harmless from any liability or damage whatsoever arising out of the use of the Product(s) in such a manner.

RETURN REQUESTS/INQUIRIES

Direct all warranty and repair requests/inquiries to the OMEGA Customer Service Department. BEFORE RETURNING ANY PRODUCT(S) TO OMEGA, PURCHASER MUST OBTAIN AN AUTHORIZED RETURN (AR) NUMBER FROM OMEGA'S CUSTOMER SERVICE DEPARTMENT (IN ORDER TO AVOID PROCESSING DELAYS). The assigned AR number should then be marked on the outside of the return package and on any correspondence.

The purchaser is responsible for shipping charges, freight, insurance and proper packaging to prevent breakage in transit.

FOR **WARRANTY** RETURNS, please have the following information available BEFORE contacting OMEGA:

1. Purchase Order number under which the product was PURCHASED,
2. Model and serial number of the product under warranty, and
3. Repair instructions and/or specific problems relative to the product.

FOR **NON-WARRANTY** REPAIRS, consult OMEGA for current repair charges. Have the following information available BEFORE contacting OMEGA:

1. Purchase Order number to cover the COST of the repair,
2. Model and serial number of the product, and
3. Repair instructions and/or specific problems relative to the product.

OMEGA's policy is to make running changes, not model changes, whenever an improvement is possible. This affords our customers the latest in technology and engineering.

OMEGA is a trademark of OMEGA ENGINEERING, INC.

© Copyright 2019 OMEGA ENGINEERING, INC. All rights reserved. This document may not be copied, photocopied, reproduced, translated, or reduced to any electronic medium or machine-readable form, in whole or in part, without the prior written consent of OMEGA ENGINEERING, INC.

Where Do I Find Everything I Need for Process Measurement and Control? **OMEGA...Of Course!** *Shop online at omega.com*

TEMPERATURE

- Thermocouple, RTD & Thermistor Probes, Connectors, Panels & Assemblies
- Wire: Thermocouple, RTD & Thermistor
- Calibrators & Ice Point References
- Recorders, Controllers & Process Monitors
- Infrared Pyrometers

PRESSURE, STRAIN AND FORCE

- Transducers & Strain Gages
- Load Cells & Pressure Gages
- Displacement Transducers
- Instrumentation & Accessories

FLOW/LEVEL

- Rotameters, Gas Mass Flowmeters & Flow Computers
- Air Velocity Indicators
- Turbine/Paddlewheel Systems
- Totalizers & Batch Controllers

pH/CONDUCTIVITY

- pH Electrodes, Testers & Accessories
- Benchtop/Laboratory Meters
- Controllers, Calibrators, Simulators & Pumps
- Industrial pH & Conductivity Equipment

DATA ACQUISITION

- Communications-Based Acquisition Systems
- Data Logging Systems
- Wireless Sensors, Transmitters, & Receivers
- Signal Conditioners
- Data Acquisition Software

HEATERS

- Heating Cable
- Cartridge & Strip Heaters
- Immersion & Band Heaters
- Flexible Heaters
- Laboratory Heaters

ENVIRONMENTAL MONITORING AND CONTROL

- Metering & Control Instrumentation
- Refractometers
- Pumps & Tubing
- Air, Soil & Water Monitors
- Industrial Water & Wastewater Treatment
- pH, Conductivity & Dissolved Oxygen Instruments